

DISTRICT MEDICAL OFFICE OF HEALTH  
CIVIL STATION; KOLLAM – 691 013

Ph: 0474-2795017;

Email: [dmohkollam@gmail.com](mailto:dmohkollam@gmail.com)

C5/9366/2019/DMOHK

12/06/2019

HEATH AND SANITATION CERTIFICATE

This is to certify that an inspection team headed by Sri. Narayanan, Technical Assistant in charge from this office has inspected the TKM Centenary Public School, Karicode, Kollam on 27/5/2019. The team found that the school has safe drinking water facilities for the students and other staff members and is maintaining hygienic sanitation conditions in the building and campus as per the Rules and Regulations of Public Health Act.

This certificate is issued to be produced before the CBSE Authorities, New Delhi and the validity of the same is a period of one year from the date of issue.



*[Handwritten Signature]*  
Dr. V.V. Sherly,

District Medical Officer (Health), Kollam

The Principal,  
TKM Centenary Public School,  
Karicode, Kollam - 691 005  
Kerala

*[Handwritten Signature]*

Manager

T.K.M. Centenary Public School  
Kollam - 691 005



*[Handwritten Signature]*  
MRS.P.SABOORA BEGUM  
PRINCIPAL  
TKM CENTENARY PUBLIC SCHOOL  
KARICODE, KOLLAM - 691 005, KERALA

सी इ पी सी आई प्रयोगशाला  
एवं अनुसंधान संस्थान

CEPCI LABORATORY &  
RESEARCH INSTITUTE

ACCREDITED AS PER  
ISO/IEC 17025:2005



NABL Certificate No  
TC - 6088

काश्यू भवन, मुन्टखकल, कोल्लम- 691001, केरल, भारत. CIN : U74999KL1955NPL000300  
Cashew Bhavan Mundakkal, Kollam - 691 001, Kerala, India Tel +91 474 2761003 2742704  
Fax +91 474 2742704. Email: cepclab@cashewindia.org web: www.cepclab.org.in

**TEST CERTIFICATE  
ORIGINAL**

Date 03 May 2019

ULR - TC608819000004130P

No 1420

CUSTOMER ADDRESS	SAMPLE DETAILS
Name & Address : T K M Centenary Public School T K M C P.O, Karicode, Kollam	Reg.No : CEPC/342/19-20 Customer Reference : Letter dtd.30.04.2019 Sampling details : Direct Identification Code :-
Other details if any :	Type of Sample : Well water Sample Description : Colourless liquid with tiny suspended particles Condition of the sample : Satisfactory Date of Receipt : 30 Apr 2019 Date of Starting : 30 Apr 2019 Date of Completion : 03 May 2019 Condition of packing : Unsealed plastic bottle

Table 1. Organoleptic and physical Parameters

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Colour ,Hazan Unit	1	IS 3025 (part 4):2002	5
II	Odour	Agreeable	IS 3025 (part 5):2002	Agreeable
III	pH	5.4	IS 3025 (part 11):2002	6.5 -8.5
IV	Turbidity ,NTU	Not Detected(Det. Limit :0.2)	IS 3025 (part 10):2002	1
V	Total dissolved solids ,mg/l	122	IS 3025 (part 16):2002	500

Table 2. General Parameters Concerning Substances Undesirable in Excessive Amounts

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)

AJINI. A.S  
Scientist

Page 1 of 2

AUTHORISED SIGNATORY  
  
MAYARANI. C.B  
Assistant Principal Scientist

- This Test Certificate refers only to the item tested
- This Certificate, if reproduced shall only be in full.
- Written approval of the Lab-in-charge is necessary for reproduction of this certificate.





सी इ पी सी आई प्रयोगशाला  
एवं अनुसंधान संस्थान

CEPCI LABORATORY &  
RESEARCH INSTITUTE

ACCREDITED AS PER  
ISO / IEC 17025 : 2005



NABL Certificate No  
TC - 6088

ORIGINAL

Date : 03 May 2019

ULR - TC608819000004130P

No : 1420


Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Chloride (as Cl) ,mg/l	21.4	IS 3025 (part 32):1992	250
II	Fluoride (as F) ,mg/l	Not Detected(Det. Limit :0.1) :	IS 3025 (part 60):2008	1
III	Iron (as Fe) ,mg/l	Not Detected(Det. Limit :0.1)	IS 3025 (part 53) :2003	0.3
IV	Total Hardness (as CaCO <sub>3</sub> ) ,mg/l	Not Detected(Det. Limit :1.0)	IS 3025 (Part21):1996	200

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	* Electrical Conductivity ,ms/cm	0.1	APHA	

Microbiological Analysis


Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Total Coliforms ,Presence/Absence in 100 ml	Present	IS 15185:2016/ISO 9308-1:2014	Absent in 100 ml
II	Thermotolerant Coliforms ,Presence/Absence in 100 ml	Absent	IS 15185:2016/ISO 9308-1:2014	Absent in 100 ml
III	Escherichia coli ,Presence/Absence in 100 ml	Absent	IS 15185:2016/ISO 9308-1:2014	Absent in 100ml

Note : The test report is as per the details and samples provided to this laboratory in Kollam.  
The test marked with \* mark is not accredited by NABL

  
MRS.P.SABOORA BEGUM  
PRINCIPAL  
TKM CENTENARY PUBLIC SCHOOL  
KARICODE, KOLLAM - 691 005, KERALA

-- End of Report --

Page 2 of 2

  
AJINI, A.S  
Scientist



  
Manager  
T.K.M. Centenary Public School  
Kollam - 691 005

  
AUTHORISED SIGNATORY  
MAYARANI, C.B  
Assistant Principal Scientist